

TABLE NO. 1 - VKS
INSULATED CONDUCTOR SYSTEM

<u>DESCRIPTION</u>	<u>TYPE</u>	<u>RATING</u>	
Contact Conductor	VKS 3,4,5,6,7,8,9,10/10	10 A, 600 V ac	Fig. 1
	VKS 3,4,5,6,7,8,9,10/60	60 A, 600 V ac	
	VKS 3,4,5,6,7,8,9,10/100	100 A, 600 V ac	
	VKS 3,4,5,6,7,8,9,10/120	120 A, 600 V ac	
	VKS 3,4,5,6,7,8,9,10/140	140 A, 600 V ac 80% duty cycle	
	VKS 7,8,9,10/200	200 A, 600 V ac	
	VKS 7,8,9,10/240	240 A, 600 V ac	
	VKS 7,8,9,10/280	280 A, 600 V ac 80% duty cycle	
*Joint	SVN 3,4,5,6/10-60	10-60 A, 600 V ac	Fig. 3
	SVN 3,4,5,6/100-120	100-120 A, 600 V ac	
	SVN 3,4,5,6,7,8,9,10/60-100	60-100 A,	
	SVN 3,4,5,6,7,8,9,10/120-140	120-140 A, 600 V ac 80% duty cycle	
Feed Terminal	VEKS 3, 4, 5, 6/10 R or L	10 A, 600 V ac	Figs. 4,5,6
	VEKS 3, 4, 5, 6/60 R or L	60 A, 600 V ac	
	VEKS 3, 4, 5, 6/100 R or L	100 A, 600 V ac	
	VEKS 3, 4, 5, 6/120 R or L	120 A, 600 V ac	
	VEKS 7,8,9,10/140 R or L	140 A, 600 V ac 80% duty cycle	
	VNS 3, 4, 5, 6,10/10	10 A, 600 V ac	
	VNS 3, 4, 5, 6,10/60	60 A, 600 V ac	
	VNS 3, 4, 5, 6,10/100	100 A, 600 V ac	
	VNS 3, 4, 5, 6,10/120	120 A, 600 V ac	
	VNS 3,4,5,6,7,8,9,10/140	140 A, 600 V ac 80% duty cycle	
	VLS 3, 4, 5, 6,10/10	10 A, 600 V ac	
	VLS 3, 4, 5, 6,7,8,9,10/60-100	60-100 A, 600 V ac	
	VLS 3, 4, 5, 6,10/100	100 A, 600 V ac	
VLS 3,4,5,6,7,8,9,10/120-140	140 A, 600 V ac 80% duty cycle		
Collector Cable	FLA 2.5	32 A, 600 V ac	Fig. 8
	FLA 4	40 A, 600 V ac	
	WFLA 2.5	20 A, 600 V ac	
	FLA6	55 A, 600 V ac	
Expansion Section	DVKS 3, 4/10	10 A, 600 V ac	Fig. 2
	DVKS 3, 4/60	60 A, 600 V ac	
	DVKS 3, 4/100	100 A, 600 V ac	
	DVKS 3, 4/120	120 A, 600 V ac	
Hanger	VEPS 3, 4, 6,10	Non-electrical	Fig. 7
	VAS 3, 4, 6	Non-electrical	
	VES 3, 4, 6	Non-electrical	

M.V.
R.W.

